

SEWER AUTHORITY MID-COASTSIDE  
Staff Report

---

---

**Subject / Title**

Authorize Manager to Purchase Breaker from Eaton Electric

---

---

**Staff Recommendation:**

Authorize Manager to Purchase Breaker from Eaton Electric

---

**Fiscal Impact:**

\$41,194. \$60,000 was budgeted for this item.

---

**Discussion/Report:**

The plant's main breaker is the only distribution breaker without a backup unit. All of the electricity used in the plant passes through the main breaker. In the event that the main breaker is damaged or broken, no backup unit is available as with all other distribution breakers.

Purchase of this backup unit would allow changing out the breaker rather than running on generator power until the breaker could be repaired.

The costs for this expenditure are allocated to the Member Agencies based on capacity rights.

There are no attachments to this staff report.